



Madison County Building Department
410 N. Main St, Madison VA 22727; Phone: (540) 948-6102
Mailing address: PO Box 1206, Madison VA 22727
Website: www.madisonco.virginia.gov

Swimming Pool-Hot Tub-Spa Hydrostatic Test Report & Affidavit

Per the Virginia Uniform Statewide Building Code and the International Swimming Pool and Spa Code, a hydrostatic pressure test is required.

311.9 Hydrostatic pressure test.

Circulation system piping, other than that integrally included in the manufacture of the pool or spa, shall be subjected to a hydrostatic pressure test of 25 pounds per square inch (psi) (172.4 kPa). This pressure shall be held for not less than 15 minutes.

| | |
|---------------|--|
| Date | |
| Permit Number | |
| E911 Address | |
| Owner Name | |

By signing this Report and Affidavit, you are certifying and attesting that a hydrostatic pressure test has been performed and met the requirements as listed above.

| | |
|---------------------------|--|
| Name | |
| Contractor License Number | |
| Signature | |