



Temporary Tent Installations

Code: 2012 USBC / IBC / IFC

1. Tents 900 sq. ft. or less do not require a permit unless occupancy exceeds 50 persons.
2. Temporary tents shall comply with the International Fire Code Chapter 31-VCC 3103.1.
3. Temporary tent exits and their distribution shall comply with IFC 3103.12. Exit signs shall be installed for occupant loads of 50 or more-IFC 3103.12.6 Means of egress illumination shall comply with IFC 3103.12.7.
4. Smoking shall not be permitted within tents. Approved "No Smoking" signs shall be conspicuously posted throughout tents – IFC 3104.6
5. Portable fire extinguishers shall be provided as required by IFC 3104.12. The minimum size of extinguishers shall be 2A:10B:C and distributed in Accordance with IFC 906.3
6. Flame resistant certification shall be submitted to the code official before permit issuance in accordance with IFC 3104.2.
7. Temporary tent access, location and parking shall comply with IFC 3103.8